



中国国家强制性产品认证证书

证书编号：2024010307656807

认证委托人名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产者名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产企业名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区寺前路3号

产品名称和系列、型号、规格
塑料外壳式断路器
SL7N-125D、SL7N-125DH、SL7N-125M、SL7N-125H、SL7N-125HU；详见附页

产品标准和技术要求
GB/T 14048.2-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2024年07月12日 有效期至：2029年07月11日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010307656807

证书附页: 第 1 页 共 2 页

SL7N-125D、SL7N-125DH、SL7N-125M、SL7N-125H、SL7N-125HU;

SL7N-125D、SL7N-125DH

Ui: 690V(1P 外形)、1250V(2P 外形)、1600V(3P 外形、4P 外形); Uimp: 6kV(1P 外形、2P 外形)、8kV(3P 外形、4P 外形);

Ue(In: 6A~80A): DC48~250V/375V/440V/600V(1P 外形); DC750V/800V/1000V(2P 外形); DC1200V/1500V(3P 外形); DC1500V(4P 外形); Ue(In: 100A~125A): DC48~250V(1P 外形); DC375V/440V/600V(2P 外形); DC750V/800V(3P 外形); DC1000V/1200V(4P 外形);

In: 6A、10A、16A、20A、25A、32A、40A、50A、63A、80A、100A、125A; Ics=Icu: 2kA (SL7N-125D); Ics=Icu: 6kA (SL7N-125DH); 过电流脱扣器类型: 热磁式; 选择性类别: A 类; 接线方式: 1P 外形、2P 外形、3P 外形、4P 外形 (均为保护极, 适用于隔离); 适用于 PV;

SL7N-125M、SL7N-125H、SL7N-125HU;

Ui: 1000V; Uimp: 8kV; SL7N-125M、SL7N-125H: Ue: AC230V(1P)、AC400V(2P、3P、4P); SL7N-125HU: Ue: AC230V(1P)、AC400V(2P)、AC690V/800V(3P、4P); In: 6A、10A、16A、20A、25A、32A、40A、50A、63A、80A、100A、125A (仅 SL7N-125M 有 100A、125A);

Ics=Icu: 6kA (SL7N-125HU); Ics=Icu: 10kA (SL7N-125M); Ics=Icu: 15kA (SL7N-125H); 过电流脱扣器类型: 热磁式; 选择性类别: A 类; 极数: 1P、2P、3P、4P (均为保护极, 适用于隔离用); 50Hz/60Hz;

辅助电路: 1N01NC; AC-15 Ue/Ie: AC250V/6A; DC-13 Ue/Ie: DC60V/4A; Ith: 8A; Ui: 250V; Uimp: 2.5kV。

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2024010307656807

证书附页：第 2 页 共 2 页

型号的解释：

SL 7N - 125 □ □ □
(1) (2) (3) (4) (5) (6)

- (1) 企业代号
- (2) 设计序号
- (3) 壳架等级额定电流 (A)
- (4) 电流种类:无: 交流型; D: 直流型
- (5) 分断级别: 无: 低分断; M: 较高分断; H: 高分断
- (6) 交流电压类别: 无: 普通电压; HU: 高电压

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307656807

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Xinchi Electric Group Co., Ltd.
No.3 Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Moulded case Circuit-breaker
SL7N-125D、SL7N-125DH、SL7N-125M、SL7N-125H、SL7N-125HU ; See the appendix.

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.12,2024

Valid until: Jul.11,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010307656807

Appendix: Page 1 of 2

SL7N-125D、SL7N-125DH、SL7N-125M、SL7N-125H、SL7N-125HU ;

SL7N-125D、SL7N-125DH

Ui :690V(1P Shape)、1250V(2P Shape)、1600V(3P Shape、4P Shape) ;Uimp :6kV(1P Shape、2P Shape)、8kV(3P Shape、4P Shape) ;

Ue(In : 6A~80A) : DC48~250V/375V/440V/600V(1P Shape) ;
DC750V/800V/1000V(2P Shape) ;DC1200V/1500V(3P Shape) ;DC1500V(4P Shape) ;

Ue(In : 100A~125A) : DC48~250V(1P Shape) ; DC375V/440V/600V(2P Shape) ;
DC750V/800V(3P Shape) ; DC1000V/1200V(4P Shape) ;

In : 6A、10A、16A、20A、25A、32A、40A、50A、63A、80A、100A、125A ;

Ics=Icu : 2kA (SL7N-125D) ; Ics=Icu : 6kA (SL7N-125DH) ; Over-current Release

Type:TMU ; Selectivity category : A ; Connection Mode : 1P Shape、2P Shape、
3P Shape、4P Shape(All are protected poles ,Suitable for isolation) ;Applies to PV ;

SL7N-125M、SL7N-125H、SL7N-125HU ;

Ui :1000V ;Uimp :8kV ;SL7N-125M、SL7N-125H :Ue :AC230V(1P)、AC400V(2P、
3P、4P) ; SL7N-125HU : Ue : AC230V(1P)、AC400V(2P)、AC690V/800V(3P、
4P) ;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307656807

Appendix: Page 2 of 2

In : 6A、10A、16A、20A、25A、32A、40A、50A、63A、80A、100A、125A

(Only SL7N-125M has 100A and 125A);

Ics=Icu : 6kA (SL7N-125HU); Ics=Icu : 10kA (SL7N-125M); Ics=Icu : 15kA

(SL7N-125H); Over-current Release Type:TMU ; Selectivity category : A ; Poles :

1P、2P、3P、4P (All are protected poles , Suitable for isolation); 50Hz/60Hz ;

Auxiliary circuit :1NO1NC ;AC-15 Ue/Ie :AC250V/6A ;DC-13 Ue/Ie :DC60V/4A ;

Ith : 8A ; Ui : 250V ; Uimp : 2.5kV。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation