



中国国家强制性产品认证证书

证书编号：2024010302657748

认证委托人名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产者名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产企业名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区寺前路3号

产品名称和系列、型号、规格
直流隔离开关

SDS15-32; Uimp: 8kV; Ui: 1500V; Ith: 32A; Ue: DC1000V、DC800V、DC600V;
Ie: 10A、16A、20A、26A、32A; Icw: 1.0kA 1s; Icm: 1.7kA; 使用类别: DC-PV1、
DC-21B; 外壳防护等级: IP20; 直流接线方式详见附件

产品标准和技术要求
GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2024年07月15日 有效期至: 2029年07月14日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302657748

证书附页：第 1 页 共 2 页

直流接线方式示意图如下：

SDS15-32		负载图
接线简称	接线方式	
4	4 层接 2 负载	
6	6 层接 3 负载	
8	8 层接 4 负载	

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号: 2024010302657748

证书附页: 第 2 页 共 2 页

型号的解释:

$\frac{S}{(1)}$ $\frac{DS}{(2)}$ $\frac{15}{(3)}$ - $\frac{32}{(4)}$ / $\frac{\square}{(5)}$ $\frac{\square}{(6)}$

- (1) 企业代号
- (2) 直流隔离开关
- (3) 设计序号
- (4) 壳架等级电流
- (5) 层数: 4P-4 层、6P-6 层、8P-8 层
- (6) 额定电流 (A): 10、16、20、26、32

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302657748

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Xinchi Electric Group Co., Ltd.
No 3.Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

DC switch-disconnectors
SDS15-32; Uimp : 8kV ; Ui : 1500V ; Ith : 32A ; Ue : DC1000V、DC800V、DC600V ; Ie : 10A、
16A、20A、26A、32A ; Icw : 1.0kA 1s ; Icm : 1.7kA ; Utilization Category : DC-PV1、DC-21B ;
Levels of Protection : IP20 ; See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.15,2024

Valid until: Jul.14,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010302657748

Appendix: Page 1 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

The schematic diagram of the DC wiring method is as follows:

SDS15-32		负载图
接线简称	接线方式	
4	4 层接 2 负载	
6	6 层接 3 负载	
8	8 层接 4 负载	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010302657748

Appendix: Page 2 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

型号的解释:

$\frac{S}{(1)}$ $\frac{DS}{(2)}$ $\frac{15}{(3)}$ $-$ $\frac{32}{(4)}$ $/$ $\frac{\square}{(5)}$ $\frac{\square}{(6)}$

- (1) 企业代号
- (2) 直流隔离开关
- (3) 设计序号
- (4) 壳架等级电流
- (5) 层数: 4P-4 层、6P-6 层、8P-8 层
- (6) 额定电流 (A): 10、16、20、26、32

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.